

## TECHNICAL SPECIFICATION

|  |                             |                              |                          |                          |
|--|-----------------------------|------------------------------|--------------------------|--------------------------|
| FIRE EXTINGUISHER CAPACITY                               | 6 ltr.                      | 9 ltr.                       | 45 ltr.                  | 9 ltr.                   |
| MINIMUM PERIOD FOR WHICH<br>THROW OF JET MAINTAINED      | (Stored Pressure)<br>25 sec | (Stored Pressure)<br>100 sec | (Catridg Type)<br>60 sec | (Catridg Type)<br>60 sec |
| MINIMUM PERIOD TO DISCHARGES<br>AT LEAST 90% OF CONTESTS | 60 sec                      | 120 sec                      | 180 sec                  | 180 sec                  |
| RANGE OF JET   | 4 mtr.                      | 6 mtr.                       | 10 mtr.                  | 10 mtr.                  |
| EMPTY. WT (APPROX)                                       | 3.2 kg                      | 5.35 kg                      | 35 kg                    | 35 kg                    |
| FULL WT. (APPROX)  | 9.2 kg                      | 14.35 kg                     | 80 kg                    | 80 kg                    |
| FIRE RATING  | 3 A                         | 3 A                          | NA                       | 3 A                      |
| WORKING PRESSURE   | 15 KGF/CM <sup>2</sup>      | 15 KGF/CM <sup>2</sup>       | 15 KGF/CM <sup>2</sup>   | 15 KGF/CM <sup>2</sup>   |
| HYDRO PRESSURE   | 35 KGF/CM <sup>2</sup>      | 35 KGF/CM <sup>2</sup>       | 30 KGF/CM <sup>2</sup>   | 30 KGF/CM <sup>2</sup>   |
| BRUSTING PRESSURE  | 55 KGF/CM <sup>2</sup>      | 55 KGF/CM <sup>2</sup>       | 45 KGF/CM <sup>2</sup>   | 45 KGF/CM <sup>2</sup>   |